


OFFICE OF THE EXECUTIVE ENGINEER
RWS&S DIVISION, ANGUL:AT:TALCHER
(Ph. No./Fax-06760-240762, E-mail : eerwssang@gmail.com)

-X-X-X-X-X-X-

CERTIFICATE OF SAFE DRINKING WATER AND SANITARY CONDITION

It is certified that an inspection team of Rural Water Supply and Sanitation of Govt. of Odisha, RWS&S Division, Angul at Talcher inspected the campus of Delhi Public School, Nalco Nagar, Angul, Odisha on 25th March 2022 collected water samples from Tanks & Taps examined and found safe for the students and members of the Teaching and non-teaching staff of the institution.


Name. Er. B.R. Panda
Designation: Executive Engineer
RWS&S Division, Angul:at:Talcher

To,
The Principal
Delhi Public School
Nalco Nagar, Angul, Odisha.

DISTRICT WATER TESTING LABORATORY, R.W.S.&S.DIVISION, Angul at Talcher,

Mob -8280408908, E-mail. -distlabangul@gmail.com



WATER ANALYSIS REPORT

TEST REPORT NO.- DWTLA-TR/DPS-50/2021-22/S-1 to S-2
ULR -
DATE OF ISSUE - 28.03.2022

Sample Particulars		Details of Sampling	
Name of the Customer :-	Principal Delhi Public School, Nalco Nagar, Angul, Odisha	Type of Source:-	Supply Water
		Date of Sampling:-	Not Specified
Sample Package Condition:- a) Quantity of Sample Received -500ml (Each) b) Type of Container - PP c) Sealed / Unsealed : Sealed		Sample receive date:- Vide letter No.	25.03.2022 / Vide letter No. 10153/ Dated . 14.03.2022
		Sample Registration Date:-	25.03.2022
		Sampling Protocol:-	Samples are not collected by this laboratory
		Sample Collected by:-	Not Specified
		Sample Location:-	1. Tank 2. Tap

TEST RESULT

Test started on-		25.03.2022		Test completed on-		26.03.2022	
Sl.	Test Parameters	Units	Results	Requirements IS 10500 : 2012		Test Method	
				Acceptable Limit	Permissible Limit in absence of alternate source		
Bacteriological Test							
1	Total Coliform Bacteria	MPN/100ml	1.. 0.0 2. 0.0	Shall not be dectable in any 100 ml Samples		Colilert - 18 / IDEXX-Quantity Tray, (Enzyme Substrate test APHA 23 rd Ed 9223-CI-B)	

Note :- The samples were tested with dilution.

Information on Test Report :

Results relates only to samples received in the Laboratory.

The test report shall not be reproduced except in full without written approval of DWTLA

#APHA - American Public Health Association

Checked & Reviewed by

[Signature]
28.03.2022
Technical Manager

[Signature]
Quality Manager 28/03/2022

District Water Testing Laboratory
RWS&S Division, Angul at Talcher
Authorised Signatory

*****End of Report*****